

DATE: 12/02/08
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
SOURCE NO: 005 NAME: WELL 03 PSCODE: 4010011-005 CLASS: LARG STATUS:
AR

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT

NI NITRATE/NITRITE						
71850 NITRATE (AS NO3)	08/20/1998	26.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/27/2000	26.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/27/2000	30.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/26/2001	41.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/13/2001	40.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/21/2002	47.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/12/2002	71.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/19/2003	83.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/08/2003	2.2000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/03/2004	34.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/12/2004	24.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	08/19/2004	77.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	08/24/2004	87.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/08/2004	98.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/28/2004	67.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/05/2004	62.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/19/2004	62.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/26/2004	54.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	04/26/2005	35.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/20/2005	27.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/15/2005	57.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	01/18/2006	47.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/06/2006	46.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/17/2006	49.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/20/2006	84.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/27/2006	86.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/28/2006	84.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/29/2006	80.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/30/2006	80.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/01/2006	77.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/04/2006	81.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/05/2006	81.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/01/2007	49.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/08/2007	55.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/19/2007	100.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	02/05/2008	72.0000 *	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
 REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
 SOURCE NO: 006 NAME: WELL 04 PSCODE: 4010011-006 CLASS: LARG STATUS:
 AR

GROUP IDENTIFICATION	SAMPLE	RESULT *	MCL	DLR	TRIGGER	UNIT
CONSTITUENT IDENTIFICATION	DATE					

 NI NITRATE/NITRITE

71850 NITRATE (AS NO3)	08/20/1998	23.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/27/2000	26.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/13/2001	30.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/21/2002	24.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/12/2002	56.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/12/2003	36.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/19/2003	65.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/03/2004	13.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/12/2004	11.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/21/2004	20.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/25/2004	24.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	08/24/2004	42.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/08/2004	50.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2004	58.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/08/2005	28.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	04/19/2005	25.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/20/2005	19.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/15/2005	38.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	01/18/2006	53.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/06/2006	36.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/17/2006	42.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/20/2006	62.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/27/2006	62.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/28/2006	61.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/29/2006	58.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/30/2006	59.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/01/2006	56.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/04/2006	59.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/05/2006	59.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/01/2007	63.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/08/2007	62.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/19/2007	75.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	02/05/2008	56.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/06/2008	56.0000 *	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
 REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
 SOURCE NO: 011 NAME: WELL 09 PSCODE: 4010011-011 CLASS: LARG STATUS:
 AR

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT

NI NITRATE/NITRITE						
71850 NITRATE (AS NO3)	01/06/1999	19.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/27/2000	8.9000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2000	15.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/13/2001	8.4000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/26/2002	10.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/16/2003	88.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/03/2004	13.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	04/19/2005	9.8000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	01/18/2006	6.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/12/2006	8.4000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2006	88.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	01/30/2007	24.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/05/2007	110.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/18/2007	54.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	02/05/2008	70.0000 *	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
 NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

1

DATE: 12/02/08
 REPORT: R-040/2-3

STATE OF CALIFORNIA
 DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
 REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
 SOURCE NO: 012 NAME: WELL 09A PSCODE: 4010011-012 CLASS: LARG STATUS:
 AR

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT

NI NITRATE/NITRITE						
71850 NITRATE (AS NO3)	08/20/1998	39.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/27/2000	9.7000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2000	11.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/13/2001	14.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/26/2002	12.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/16/2003	18.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/03/2004	8.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	04/19/2005	17.0000	45.0000	2.0000	23.0000	MG/L

71850 NITRATE (AS NO3)	12/19/2006	9.7000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	01/04/2007	9.7000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/05/2007	8.8000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/06/2007	22.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	02/05/2008	44.0000 *	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
 NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

1

DATE: 12/02/08
 REPORT: R-040/2-3

STATE OF CALIFORNIA
 DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
 REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
 SOURCE NO: 013 NAME: WELL 10 PSCODE: 4010011-013 CLASS: LARG STATUS:
 AR

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
--	----------------	----------	-----	-----	---------	------

 NI NITRATE/NITRITE

71850 NITRATE (AS NO3)	08/20/1998	17.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/27/2000	6.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2000	7.4000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/13/2001	7.3000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/26/2002	7.5000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/18/2003	13.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/16/2003	49.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/03/2004	14.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	04/26/2005	8.5000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/06/2006	5.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/12/2006	5.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2006	89.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	01/04/2007	6.6000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/05/2007	33.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/06/2007	60.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	02/05/2008	53.0000 *	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
 NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

1

DATE: 12/02/08
 REPORT: R-040/2-3

STATE OF CALIFORNIA
 DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
 REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO

SOURCE NO: 014 NAME: WELL 10A - STANDBY
STATUS: SR

PSCODE: 4010011-014 CLASS: STBY

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
--	----------------	----------	-----	-----	---------	------

NI NITRATE/NITRITE

71850 NITRATE (AS NO3)	04/12/2001	14.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/01/2008	15.0000	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

1

DATE: 12/02/08
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
SOURCE NO: 016 NAME: WELL 11A PSCODE: 4010011-016 CLASS: LARG STATUS:
AR

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
--	----------------	----------	-----	-----	---------	------

NI NITRATE/NITRITE

71850 NITRATE (AS NO3)	08/20/1998	36.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/27/2000	7.4000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2000	15.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/13/2001	14.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/23/2001	15.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/26/2002	11.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/18/2003	11.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/16/2003	9.8000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/03/2004	11.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/02/2004	7.7000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2004	8.9000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/23/2004	12.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/21/2004	14.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	02/08/2005	22.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/15/2005	18.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/12/2006	16.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/01/2006	22.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/20/2006	21.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	01/30/2007	20.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	02/06/2007	19.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/13/2007	18.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	04/10/2007	18.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/01/2007	18.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/05/2007	19.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/02/2007	12.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/30/2007	8.4000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/08/2007	11.0000	45.0000	2.0000	23.0000	MG/L

71850 NITRATE (AS NO3)	02/05/2008	13.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/11/2008	14.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	04/01/2008	13.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/07/2008	7.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/21/2008	6.8000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/06/2008	9.9000	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 12/02/08
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
SOURCE NO: 019 NAME: WELL 14 PSCODE: 4010011-019 CLASS: LARG STATUS:
AR

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT

NI NITRATE/NITRITE						
71850 NITRATE (AS NO3)	03/04/1999	28.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/27/2000	31.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/13/2001	38.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/21/2002	21.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/12/2002	30.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/12/2003	17.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/19/2003	25.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	08/19/2004	10.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	08/24/2004	12.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/08/2004	8.7000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/02/2004	8.6000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2004	11.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	02/08/2005	9.1000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/20/2005	12.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/15/2005	28.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/06/2006	29.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/17/2006	40.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/07/2006	40.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/14/2006	44.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/20/2006	38.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/22/2006	40.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/27/2006	39.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/28/2006	38.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/29/2006	37.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/30/2006	36.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/01/2006	35.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/04/2006	38.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/05/2006	39.0000 *	45.0000	2.0000	23.0000	MG/L

71850 NITRATE (AS NO3)	05/01/2007	80.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/08/2007	72.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/19/2007	54.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	02/05/2008	54.0000 *	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 12/02/08
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
SOURCE NO: 020 NAME: WELL 15 PSCODE: 4010011-020 CLASS: LARG STATUS:
AR

GROUP IDENTIFICATION	SAMPLE	RESULT *	MCL	DLR	TRIGGER	UNIT
CONSTITUENT IDENTIFICATION	DATE					

NI NITRATE/NITRITE

71850 NITRATE (AS NO3)	08/20/1998	19.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/27/2000	25.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/13/2001	13.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/21/2002	23.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/12/2002	22.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/12/2002	23.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/12/2003	20.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/03/2004	14.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/12/2004	15.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	08/19/2004	2.4000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	08/24/2004	2.4000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/08/2004	3.4000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/26/2004	3.2000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/31/2005	9.8000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/20/2005	6.7000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/15/2005	23.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/06/2006	33.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/01/2006	29.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/14/2006	35.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2006	36.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2006	43.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/20/2006	44.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/22/2006	46.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/27/2006	50.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/28/2006	49.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/29/2006	48.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/30/2006	48.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/01/2006	47.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/04/2006	51.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/05/2006	51.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/01/2007	32.0000 *	45.0000	2.0000	23.0000	MG/L

71850 NITRATE (AS NO3)	05/08/2007	34.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/11/2007	51.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/02/2007	49.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	02/05/2008	53.0000 *	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

1

DATE: 12/02/08
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
SOURCE NO: 021 NAME: WELL 16 PSCODE: 4010011-021 CLASS: LARG STATUS:
AR

GROUP IDENTIFICATION	SAMPLE	RESULT *	MCL	DLR	TRIGGER	UNIT
CONSTITUENT IDENTIFICATION	DATE					

NI NITRATE/NITRITE

71850 NITRATE (AS NO3)	08/20/1998	23.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/27/2000	6.2000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2000	6.2000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2000	6.2000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/13/2001	8.7000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/26/2002	7.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/18/2003	7.6000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/16/2003	7.6000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/03/2004	13.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	04/19/2005	.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/12/2006	8.4000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2006	8.4000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2006	7.5000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/17/2006	7.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	01/04/2007	2.6000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	01/30/2007	7.9000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	02/06/2007	7.5000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	03/13/2007	6.2000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	04/10/2007	7.5000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/01/2007	7.5000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/05/2007	6.6000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/02/2007	39.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/30/2007	55.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/06/2007	51.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	02/05/2008	33.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	04/29/2008	11.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	05/06/2008	14.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	09/23/2008	18.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/07/2008	29.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/08/2008	44.0000 *	45.0000	2.0000	23.0000	MG/L

71850 NITRATE (AS NO3)	10/13/2008	41.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/14/2008	51.0000 *	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
 NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

1

DATE: 12/02/08
 REPORT: R-040/2-3

STATE OF CALIFORNIA
 DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
 REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
 SOURCE NO: 022 NAME: DESAL RAW - SEAWATER - STANDBY PSCODE: 4010011-022 CLASS:
 STBY STATUS: SR

GROUP IDENTIFICATION	SAMPLE	RESULT *	MCL	DLR	TRIGGER	UNIT
CONSTITUENT IDENTIFICATION	DATE					

NI NITRATE/NITRITE						
71850 NITRATE (AS NO3)	10/29/2002	.0000	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
 NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 12/02/08
 REPORT: R-040/2-3

STATE OF CALIFORNIA
 DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
 REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
 SOURCE NO: 023 NAME: DESAL TREATED (RO) PSCODE: 4010011-023 CLASS: DEAD
 STATUS: AT

GROUP IDENTIFICATION	SAMPLE	RESULT *	MCL	DLR	TRIGGER	UNIT
CONSTITUENT IDENTIFICATION	DATE					

NI NITRATE/NITRITE						
71850 NITRATE (AS NO3)	11/17/2006	2.6000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/27/2006	3.5000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/28/2006	3.5000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	12/07/2006	2.6000	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

1

DATE: 12/02/08
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
SOURCE NO: 027 NAME: QUINTANA NITRATE BLEND PSCODE: 4010011-027 CLASS: DEAD
STATUS: CT

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
--	----------------	----------	-----	-----	---------	------

NI NITRATE/NITRITE						
71850 NITRATE (AS NO3)	10/23/2001	15.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/30/2001	12.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/06/2001	5.3000	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

1

DATE: 12/02/08
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19980101 THRU 20081202
REPORT OF COUNTY: 40 SAN LUIS OBISPO

SYSTEM NO: 4010011 NAME: MORRO BAY WATER DEPARTMENT COUNTY: SAN LUIS OBISPO
SOURCE NO: 028 NAME: KINGS TANK BLEND - TREATED PSCODE: 4010011-028 CLASS:
DEAD STATUS: AT

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
--	----------------	----------	-----	-----	---------	------

NI NITRATE/NITRITE						
71850 NITRATE (AS NO3)	03/08/2005	19.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	04/19/2005	19.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/15/2005	30.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/17/2005	32.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	06/27/2006	13.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/05/2006	18.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2006	49.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/16/2006	46.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/17/2006	32.0000 *	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/17/2006	8.8000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/20/2006	11.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/28/2006	5.7000	45.0000	2.0000	23.0000	MG/L

71850 NITRATE (AS NO3)	01/03/2007	12.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	04/10/2007	16.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	10/02/2007	7.0000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	11/19/2007	3.1000	45.0000	2.0000	23.0000	MG/L
71850 NITRATE (AS NO3)	07/01/2008	6.2000	45.0000	2.0000	23.0000	MG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD